



# Certificate of Compliance

**Certificate:** 1701492 (LR 104031)

**Master Contract:** 182407

**Project:** 2328692

**Date Issued:** September 3, 2010

**Issued to:** Hummel AG

Lise-Meitner-Straße 2

Denzlingen, 79211

Germany

Attention: Fritz Zuegel

*The products listed below are eligible to bear the CSA Mark shown*



*Johann Borabon*

**Issued by:** Johann Borabon

## **PRODUCTS**

**CLASS 6233 02** - RECEPTACLES - Special Use Connectors

Special-use M16, Series 78XX male and female connectors, rated 9A max, 600V (3-Poles); 6A max, 300V (10-Poles), for use with Nos 18-28 AWG.

Notes:

1. Devices are intended for disconnecting use only and not for interrupting current.
2. Supplied only to manufacturers, as components, for the assembly of Certified electrical equipment, where the acceptability of the combination is to be determined in the end use.
3. The letters "XX" in the Series are replaced by alphanumeric characters.
4. Suffixes are added to the Series designations.

## **APPLICABLE REQUIREMENTS**

CSA Std C22.2 No. 182.3-M1987 - Special Use Attachment Plugs, Receptacles, and Connectors